

Отчет о суточных параметрах  
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Гагарина б-р, д. 81/2 (ООО "УК "МАСТЕР КОМФОРТА")  
Прибор: Карат-30X Заводской номер: 13221721  
Точка измерения: Подсистема 1; Ресурс: TC

Схема измерений: Пользовательская схема узла учета потребителя

| Дата       | t1    | t2    | dt    | V1       | V2       | M1       | M2       | P1      | P2      | %     | Q1     | Траб  | NS | igNSCode |
|------------|-------|-------|-------|----------|----------|----------|----------|---------|---------|-------|--------|-------|----|----------|
|            | °C    | °C    | °C    | м3       | м3       | т        | т        | кгс/см2 | кгс/см2 | т     | Гкал   | ч     |    |          |
| 01.03.2025 | 57.87 | 47.30 | 10.57 | 194.853  | 194.653  | 191.851  | 192.646  | 5.72    | 5.40    | -0.41 | 2.028  | 24.0  |    | Ok       |
| 02.03.2025 | 57.16 | 46.89 | 10.27 | 194.786  | 194.641  | 191.855  | 192.668  | 5.73    | 5.41    | -0.42 | 1.971  | 24.0  |    | Ok       |
| 03.03.2025 | 57.86 | 47.37 | 10.49 | 194.766  | 194.628  | 191.768  | 192.615  | 5.71    | 5.40    | -0.44 | 2.012  | 24.0  |    | Ok       |
| 04.03.2025 | 59.19 | 48.19 | 11.00 | 194.839  | 194.568  | 191.707  | 192.485  | 5.71    | 5.40    | -0.41 | 2.110  | 24.0  |    | Ok       |
| 05.03.2025 | 60.84 | 49.28 | 11.56 | 194.791  | 194.498  | 191.492  | 192.319  | 5.70    | 5.39    | -0.43 | 2.215  | 24.0  |    | Ok       |
| 06.03.2025 | 59.10 | 48.25 | 10.84 | 194.739  | 194.529  | 191.618  | 192.441  | 5.71    | 5.40    | -0.43 | 2.079  | 24.0  |    | Ok       |
| 07.03.2025 | 58.81 | 48.08 | 10.73 | 194.670  | 194.493  | 191.577  | 192.421  | 5.70    | 5.38    | -0.44 | 2.056  | 24.0  |    | Ok       |
| 08.03.2025 | 60.24 | 48.80 | 11.44 | 191.518  | 191.230  | 188.325  | 189.121  | 4.66    | 4.36    | -0.42 | 2.154  | 24.0  |    | Ok       |
| 09.03.2025 | 60.85 | 49.19 | 11.66 | 190.743  | 190.437  | 187.499  | 188.299  | 4.45    | 4.14    | -0.43 | 2.188  | 24.0  |    | Ok       |
| 10.03.2025 | 57.09 | 46.97 | 10.12 | 193.788  | 193.626  | 190.870  | 191.649  | 4.53    | 4.21    | -0.41 | 1.930  | 24.0  |    | Ok       |
| 11.03.2025 | 55.28 | 45.79 | 9.50  | 194.877  | 194.811  | 192.128  | 192.932  | 5.62    | 5.30    | -0.42 | 1.826  | 24.0  |    | Ok       |
| 12.03.2025 | 51.54 | 43.10 | 8.44  | 190.744  | 190.670  | 188.404  | 189.054  | 5.55    | 5.25    | -0.34 | 1.589  | 24.0  |    | Ok       |
| 13.03.2025 | 50.30 | 42.30 | 8.00  | 190.480  | 190.523  | 188.256  | 188.976  | 5.56    | 5.26    | -0.38 | 1.506  | 24.0  |    | Ok       |
| 14.03.2025 | 46.72 | 39.49 | 7.22  | 169.112  | 168.970  | 167.316  | 167.716  | 4.57    | 4.28    | -0.24 | 1.242  | 24.0  | *  | min; HC  |
| 15.03.2025 | 46.80 | 40.20 | 6.60  | 198.435  | 198.182  | 196.429  | 196.740  | 4.69    | 4.37    | -0.16 | 1.297  | 24.0  |    | Ok       |
| 16.03.2025 | 51.67 | 43.31 | 8.36  | 198.357  | 197.939  | 195.902  | 196.239  | 4.85    | 4.52    | -0.17 | 1.638  | 24.0  |    | Ok       |
| 17.03.2025 | 51.55 | 43.39 | 8.16  | 198.249  | 197.948  | 195.814  | 196.243  | 4.92    | 4.60    | -0.22 | 1.598  | 24.0  |    | Ok       |
| 18.03.2025 | 55.77 | 46.09 | 9.68  | 198.309  | 197.916  | 195.454  | 195.973  | 4.69    | 4.36    | -0.27 | 1.892  | 24.0  |    | Ok       |
| 19.03.2025 | 57.48 | 47.35 | 10.14 | 198.391  | 197.994  | 195.364  | 195.939  | 4.69    | 4.36    | -0.29 | 1.981  | 24.0  |    | Ok       |
| 20.03.2025 | 54.88 | 45.57 | 9.31  | 198.338  | 198.018  | 195.574  | 196.123  | 4.73    | 4.40    | -0.28 | 1.821  | 24.0  |    | Ok       |
| 21.03.2025 | 55.43 | 45.86 | 9.56  | 198.309  | 197.962  | 195.490  | 196.037  | 4.70    | 4.37    | -0.28 | 1.870  | 24.0  |    | Ok       |
| 22.03.2025 | 54.49 | 45.30 | 9.19  | 198.202  | 197.905  | 195.479  | 196.034  | 4.64    | 4.31    | -0.28 | 1.797  | 24.0  |    | Ok       |
| 23.03.2025 | 52.41 | 43.87 | 8.54  | 198.146  | 197.926  | 195.627  | 196.178  | 4.70    | 4.38    | -0.28 | 1.671  | 24.0  |    | Ok       |
| 24.03.2025 | 49.54 | 42.01 | 7.53  | 198.037  | 197.884  | 195.787  | 196.294  | 4.79    | 4.47    | -0.26 | 1.474  | 24.0  |    | Ok       |
| 25.03.2025 | 48.60 | 41.35 | 7.25  | 196.181  | 196.046  | 194.039  | 194.522  | 4.79    | 4.47    | -0.25 | 1.407  | 24.0  |    | Ok       |
| 26.03.2025 | 47.46 | 40.50 | 6.97  | 193.552  | 193.456  | 191.536  | 192.022  | 4.68    | 4.37    | -0.25 | 1.334  | 24.0  |    | Ok       |
| 27.03.2025 | 46.75 | 40.08 | 6.67  | 193.834  | 193.792  | 191.876  | 192.390  | 4.62    | 4.31    | -0.27 | 1.280  | 24.0  |    | Ok       |
| 28.03.2025 | 45.67 | 39.38 | 6.29  | 193.763  | 193.736  | 191.902  | 192.388  | 4.59    | 4.28    | -0.25 | 1.207  | 24.0  |    | Ok       |
| 29.03.2025 | 46.98 | 40.19 | 6.79  | 193.789  | 193.753  | 191.814  | 192.340  | 4.66    | 4.35    | -0.27 | 1.301  | 24.0  |    | Ok       |
| 30.03.2025 | 47.05 | 40.40 | 6.66  | 193.816  | 193.781  | 191.834  | 192.351  | 4.66    | 4.35    | -0.27 | 1.277  | 24.0  |    | Ok       |
| 31.03.2025 | 43.73 | 38.22 | 5.51  | 194.826  | 194.922  | 193.117  | 193.652  | 4.49    | 4.17    | -0.28 | 1.063  | 24.0  | *  | HC Vmin  |
| Средние:   | 53.20 | 44.33 | 8.87  | ---      | ---      | ---      | ---      | 4.99    | 4.68    | -0.32 | ---    | ---   |    |          |
| Итого:     | ---   | ---   | ---   | 6027.241 | 6021.439 | 5947.702 | 5966.805 | ---     | ---     | ---   | 52.814 | 744.0 |    |          |

| Дата       | V1         | V2         | M1         | M2         | Q1       | Траб    |
|------------|------------|------------|------------|------------|----------|---------|
|            | м3         | м3         | т          | т          | Гкал     | ч       |
| 28.02.2025 | 113609.400 | 112944.300 | 111963.800 | 112000.100 | 1438.764 | 29844.8 |
| 31.03.2025 | 119636.700 | 118965.800 | 117911.500 | 117966.900 | 1491.578 | 30588.8 |
| Итого:     | 6027.300   | 6021.500   | 5947.700   | 5966.800   | 52.814   | 744.0   |

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Гагарина б-р, д. 81/2 (ООО "УК "МАСТЕР КОМФОРТА")  
Прибор: Карат-30X Заводской номер: 13221721  
Точка измерения: Подсистема 2; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

| Дата       | t3    | V3      | M3      | P3      | Q2     | Траб  | NS |
|------------|-------|---------|---------|---------|--------|-------|----|
|            | °C    | м3      | т       | кгс/см2 | Гкал   | ч     |    |
| 01.03.2025 | 55.83 | 7.329   | 7.213   | 6.05    | 0.388  | 24.0  |    |
| 02.03.2025 | 55.20 | 8.077   | 7.946   | 6.06    | 0.432  | 24.0  |    |
| 03.03.2025 | 55.42 | 6.986   | 6.875   | 6.07    | 0.369  | 24.0  |    |
| 04.03.2025 | 55.26 | 6.507   | 6.404   | 6.07    | 0.343  | 24.0  |    |
| 05.03.2025 | 54.72 | 6.485   | 6.383   | 6.07    | 0.342  | 24.0  |    |
| 06.03.2025 | 56.11 | 7.406   | 7.286   | 6.07    | 0.396  | 24.0  |    |
| 07.03.2025 | 56.09 | 7.199   | 7.085   | 6.07    | 0.381  | 24.0  |    |
| 08.03.2025 | 55.48 | 7.176   | 7.063   | 6.07    | 0.378  | 24.0  |    |
| 09.03.2025 | 55.81 | 8.182   | 8.052   | 6.07    | 0.433  | 24.0  |    |
| 10.03.2025 | 55.22 | 7.264   | 7.149   | 6.07    | 0.385  | 24.0  |    |
| 11.03.2025 | 55.12 | 7.441   | 7.323   | 6.08    | 0.393  | 24.0  |    |
| 12.03.2025 | 54.75 | 7.495   | 7.377   | 6.08    | 0.394  | 24.0  |    |
| 13.03.2025 | 55.29 | 8.104   | 7.977   | 6.08    | 0.426  | 24.0  |    |
| 14.03.2025 | 54.74 | 6.506   | 6.407   | 6.00    | 0.335  | 24.0  |    |
| 15.03.2025 | 54.39 | 6.842   | 6.740   | 6.07    | 0.350  | 24.0  |    |
| 16.03.2025 | 54.13 | 8.344   | 8.215   | 6.07    | 0.436  | 24.0  |    |
| 17.03.2025 | 54.12 | 7.055   | 6.946   | 6.08    | 0.368  | 24.0  |    |
| 18.03.2025 | 54.69 | 6.367   | 6.271   | 6.08    | 0.328  | 24.0  |    |
| 19.03.2025 | 52.75 | 6.771   | 6.666   | 6.06    | 0.353  | 24.0  |    |
| 20.03.2025 | 53.76 | 6.456   | 6.358   | 6.08    | 0.334  | 24.0  |    |
| 21.03.2025 | 55.44 | 7.746   | 7.625   | 6.09    | 0.406  | 24.0  |    |
| 22.03.2025 | 52.80 | 6.786   | 6.681   | 6.08    | 0.353  | 24.0  |    |
| 23.03.2025 | 54.82 | 7.821   | 7.700   | 6.08    | 0.408  | 24.0  |    |
| 24.03.2025 | 55.78 | 7.691   | 7.571   | 6.00    | 0.404  | 24.0  |    |
| 25.03.2025 | 53.96 | 6.732   | 6.628   | 6.08    | 0.351  | 24.0  |    |
| 26.03.2025 | 56.34 | 7.870   | 7.746   | 6.08    | 0.416  | 24.0  |    |
| 27.03.2025 | 55.04 | 7.315   | 7.201   | 6.08    | 0.384  | 24.0  |    |
| 28.03.2025 | 55.04 | 7.290   | 7.176   | 6.08    | 0.382  | 24.0  |    |
| 29.03.2025 | 55.10 | 7.927   | 7.803   | 6.06    | 0.415  | 24.0  |    |
| 30.03.2025 | 54.82 | 7.881   | 7.757   | 6.06    | 0.414  | 24.0  |    |
| 31.03.2025 | 54.76 | 7.761   | 7.638   | 6.07    | 0.410  | 24.0  |    |
| Средние:   | 54.93 | ---     | ---     | 6.07    | ---    | ---   |    |
| Итого:     | ---   | 226.812 | 223.264 | ---     | 11.904 | 744.0 |    |

| Дата       | V3       | M3       | Q2      | Траб    |
|------------|----------|----------|---------|---------|
|            | м3       | т        | Гкал    | ч       |
| 28.02.2025 | 8964.445 | 8845.277 | 429.124 | 29845.2 |
| 31.03.2025 | 9191.257 | 9068.541 | 441.028 | 30589.2 |
| Итого:     | 226.812  | 223.264  | 11.904  | 744.0   |

Представитель абонента

Представитель энергоснабжающей организации