

Отчет о суточных параметрах
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Гагарина б-р, д. 81/2 (ООО "УК "МАСТЕР КОМФОРТА")
Прибор: Карат-30X Заводской номер: 13221721
Точка измерения: Подсистема 1; Ресурс: TC

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	t2	dt	V1	V2	M1	M2	P1	P2	%	Q1	Траб	NS	igNSCode
	°C	°C	°C	м3	м3	т	т	кгс/см2	кгс/см2	т	Гкал	ч		
01.04.2025	43.42	38.00	5.42	196.548	196.663	194.852	195.396	4.38	4.06	-0.28	1.056	24.0		Ok
02.04.2025	44.66	38.80	5.86	196.540	196.631	194.741	195.306	4.44	4.12	-0.29	1.141	24.0		Ok
03.04.2025	46.19	39.80	6.39	196.567	196.623	194.632	195.221	4.54	4.21	-0.30	1.244	24.0		Ok
04.04.2025	47.47	40.55	6.92	196.592	196.596	194.542	195.134	4.63	4.31	-0.30	1.347	24.0		Ok
05.04.2025	45.63	39.47	6.16	196.448	196.537	194.564	195.160	4.55	4.23	-0.31	1.199	24.0		Ok
06.04.2025	48.23	41.08	7.15	196.586	196.589	194.469	195.082	4.65	4.32	-0.31	1.391	24.0		Ok
07.04.2025	48.94	41.54	7.40	196.548	196.529	194.371	194.987	4.77	4.44	-0.32	1.438	24.0		Ok
08.04.2025	45.78	39.45	6.33	196.402	196.499	194.504	195.126	4.61	4.29	-0.32	1.232	24.0		Ok
09.04.2025	43.11	37.64	5.47	196.334	196.494	194.662	195.256	4.43	4.11	-0.30	1.065	24.0		Ok
10.04.2025	46.98	40.18	6.80	198.113	198.151	196.090	196.705	4.57	4.24	-0.31	1.333	24.0		Ok
11.04.2025	45.74	38.98	6.76	162.971	162.681	161.229	161.475	5.28	5.03	-0.15	1.227	24.0	*	min; HC Tmin
12.04.2025	46.49	39.97	6.53	197.037	196.880	195.069	195.463	4.56	4.23	-0.20	1.274	24.0		Ok
13.04.2025	48.60	41.26	7.34	197.136	196.961	194.982	195.437	4.74	4.42	-0.23	1.432	24.0		Ok
14.04.2025	49.03	41.63	7.40	197.077	196.950	194.882	195.398	4.80	4.48	-0.26	1.441	24.0		Ok
15.04.2025	43.02	37.72	5.30	196.806	196.857	195.135	195.609	4.57	4.25	-0.24	1.034	24.0		Ok
16.04.2025	39.84	35.26	4.57	196.757	196.889	195.353	195.826	4.41	4.09	-0.24	0.893	24.0		Ok
17.04.2025	46.41	39.53	6.88	186.627	186.576	184.754	185.254	4.58	4.28	-0.27	1.274	24.0	*	min; HC Tmin
18.04.2025	44.62	38.60	6.02	190.164	190.178	188.416	188.909	4.53	4.22	-0.26	1.135	24.0	*	min; HC Tmin
19.04.2025	35.16	32.18	2.98	194.275	194.535	193.232	193.697	4.24	3.93	-0.24	0.577	24.0		Ok
20.04.2025	37.32	33.58	3.74	194.285	194.502	193.089	193.565	4.28	3.97	-0.25	0.721	24.0		Ok
21.04.2025	41.81	36.65	5.15	194.370	194.476	192.819	193.323	4.39	4.08	-0.26	0.994	24.0		Ok
22.04.2025	34.35	31.54	2.81	194.156	194.430	193.163	193.628	4.18	3.87	-0.24	0.542	24.0	*	HC Tmin
23.04.2025	44.72	38.69	6.04	195.487	195.524	193.687	194.214	4.48	4.16	-0.27	1.169	24.0		Ok
24.04.2025	35.55	32.58	2.98	194.034	194.282	192.964	193.419	4.16	3.84	-0.24	0.575	24.0		Ok
25.04.2025	37.75	33.89	3.86	194.131	194.336	192.903	193.384	4.20	3.89	-0.25	0.744	24.0		Ok
26.04.2025	37.26	33.67	3.60	194.085	194.319	192.893	193.382	4.15	3.84	-0.25	0.694	24.0		Ok
27.04.2025	41.94	36.71	5.23	194.269	194.377	192.709	193.219	4.34	4.03	-0.26	1.008	24.0		Ok
28.04.2025	50.99	42.79	8.20	194.556	194.430	192.210	192.803	4.60	4.29	-0.31	1.577	24.0		Ok
29.04.2025	48.01	41.07	6.94	194.117	194.120	192.043	192.636	4.62	4.31	-0.31	1.333	24.0		Ok
30.04.2025	43.02	37.31	5.71	183.452	183.525	181.884	182.381	4.31	4.01	-0.27	1.038	24.0	*	min; HC Tmin
Средние:	43.73	38.00	5.73	---	---	---	---	4.50	4.18	-0.27	---	---		
Итого:	---	---	---	5812.473	5814.143	5760.843	5776.391	---	---	---	33.127	720.0		

Дата	V1	V2	M1	M2	Q1	Траб
	м3	м3	т	т	Гкал	ч
31.03.2025	119636.700	118965.800	117911.500	117966.900	1491.578	30588.8
30.04.2025	125449.100	124779.900	123672.400	123743.300	1524.705	31308.8
Итого:	5812.400	5814.100	5760.900	5776.400	33.127	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Гагарина б-р, д. 81/2 (ООО "УК "МАСТЕР КОМФОРТА")
Прибор: Карат-30X Заводской номер: 13221721
Точка измерения: Подсистема 2; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t3	V3	M3	P3	Q2	Траб	NS
	°C	м3	т	кгс/см2	Гкал	ч	
01.04.2025	52.07	6.790	6.689	5.38	0.346	24.0	
02.04.2025	55.53	8.045	7.919	6.11	0.424	24.0	
03.04.2025	54.11	7.219	7.107	6.11	0.377	24.0	
04.04.2025	54.41	6.937	6.830	6.12	0.361	24.0	
05.04.2025	55.28	7.550	7.432	6.11	0.395	24.0	
06.04.2025	54.00	7.743	7.623	6.08	0.404	24.0	
07.04.2025	55.05	8.056	7.929	6.11	0.425	24.0	
08.04.2025	54.12	7.273	7.159	6.10	0.382	24.0	
09.04.2025	55.29	7.460	7.344	6.09	0.391	24.0	
10.04.2025	53.04	7.774	7.654	6.10	0.405	24.0	
11.04.2025	56.19	7.818	7.698	6.10	0.407	24.0	
12.04.2025	55.76	7.623	7.504	6.09	0.400	24.0	
13.04.2025	55.38	8.061	7.936	6.09	0.421	24.0	
14.04.2025	54.73	7.992	7.866	6.09	0.421	24.0	
15.04.2025	55.87	7.290	7.176	6.08	0.383	24.0	
16.04.2025	54.14	7.207	7.095	6.09	0.377	24.0	
17.04.2025	55.68	8.150	8.022	6.09	0.429	24.0	
18.04.2025	54.82	6.129	6.035	6.10	0.318	24.0	
19.04.2025	55.67	7.608	7.489	6.09	0.399	24.0	
20.04.2025	53.52	6.920	6.812	6.09	0.362	24.0	
21.04.2025	55.54	6.807	6.701	6.10	0.357	24.0	
22.04.2025	54.96	7.227	7.114	6.10	0.379	24.0	
23.04.2025	55.44	6.423	6.324	6.08	0.335	24.0	
24.04.2025	54.90	7.169	7.057	6.09	0.376	24.0	
25.04.2025	53.48	5.881	5.793	6.10	0.301	24.0	
26.04.2025	54.80	7.423	7.306	6.10	0.391	24.0	
27.04.2025	51.95	7.447	7.337	6.01	0.379	24.0	
28.04.2025	52.99	6.444	6.346	6.19	0.333	24.0	
29.04.2025	55.19	6.625	6.523	6.10	0.345	24.0	
30.04.2025	54.21	6.597	6.497	6.10	0.341	24.0	
Средние:	54.60	---	---	6.07	---	---	
Итого:	---	217.688	214.317	---	11.362	720.0	

Дата	V3	M3	Q2	Траб
	м3	т	Гкал	ч
31.03.2025	9191.257	9068.541	441.028	30589.2
30.04.2025	9408.944	9282.858	452.390	31309.2
Итого:	217.687	214.317	11.362	720.0

Представитель абонента

Представитель энергоснабжающей организации