

Отчет о суточных параметрах
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Дружбы ул, д. 23 (ООО "УК "МАСТЕР КОМФОРТА" Дружбы 23, 23а, 23б)
Прибор: ТСРВ-033(034) Заводской номер: 905596
Точка измерения: ТС1 (Дружбы, 23А); Ресурс: ТС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	t2	dt	m1	m2	%	W4	W5	W6	Тнар	Тпр	NS
	°C	°C	°C	т	т		ГКал	ГКал	ГКал	ч	ч	
01.09.2025	61.80	48.40	13.40	21.62	23.55	-8.55	0.29	0.29	0.29	24.00	0.00	
02.09.2025	63.31	52.39	10.92	25.84	28.51	-9.81	0.28	0.28	0.28	24.00	0.00	
03.09.2025	66.24	57.75	8.49	33.13	37.62	-12.69	0.27	0.27	0.27	24.00	0.00	
04.09.2025	68.67	60.43	8.24	41.54	42.47	-2.20	0.35	0.35	0.35	24.00	0.00	
05.09.2025	66.89	59.61	7.28	41.90	41.35	1.33	0.31	0.31	0.31	24.00	0.00	
06.09.2025	66.60	59.30	7.30	41.90	41.26	1.53	0.31	0.31	0.31	24.00	0.00	
07.09.2025	66.88	59.59	7.29	42.79	42.10	1.62	0.31	0.31	0.31	24.00	0.00	
08.09.2025	68.22	60.62	7.60	48.14	47.31	1.73	0.37	0.37	0.37	24.00	0.00	
09.09.2025	71.46	65.51	5.95	64.90	63.66	1.92	0.39	0.39	0.39	24.00	0.00	
10.09.2025	67.81	60.56	7.25	48.00	47.33	1.41	0.35	0.35	0.35	24.00	0.00	
11.09.2025	68.18	60.25	7.93	46.37	45.79	1.28	0.37	0.37	0.37	24.00	0.00	
12.09.2025	67.58	58.46	9.12	38.15	37.79	0.93	0.35	0.35	0.35	24.00	0.00	
13.09.2025	68.54	59.29	9.25	40.78	40.39	0.97	0.38	0.38	0.38	24.00	0.00	
14.09.2025	69.70	59.88	9.82	43.23	42.83	0.93	0.43	0.43	0.43	24.00	0.00	
15.09.2025	68.03	59.25	8.78	40.96	40.58	0.93	0.36	0.36	0.36	24.00	0.00	
16.09.2025	67.72	58.20	9.52	36.81	36.55	0.73	0.35	0.35	0.35	24.00	0.00	
17.09.2025	68.29	58.42	9.87	37.37	37.58	-0.55	0.37	0.37	0.37	24.00	0.00	
18.09.2025	69.44	60.82	8.62	31.14	43.26	-32.59	0.27	0.27	0.27	24.00	0.00	
19.09.2025	68.85	60.35	8.50	31.14	41.42	-28.34	0.26	0.26	0.26	24.00	0.00	
20.09.2025	69.18	60.51	8.67	33.02	41.31	-22.33	0.28	0.28	0.28	24.00	0.00	
21.09.2025	70.02	60.81	9.21	34.42	41.09	-17.68	0.31	0.31	0.31	24.00	0.00	
22.09.2025	67.38	57.73	9.65	33.15	36.34	-9.18	0.32	0.32	0.32	24.00	0.00	
23.09.2025	69.29	61.53	7.76	51.91	52.69	-1.49	0.40	0.40	0.40	24.00	0.00	
24.09.2025	69.95	64.54	5.41	70.55	69.63	1.31	0.39	0.39	0.39	24.00	0.00	
25.09.2025	70.14	53.15	16.99	67.83	70.16	-3.39	1.12	1.12	1.12	24.00	0.00	
26.09.2025	70.38	41.52	28.86	63.49	69.45	-8.96	1.84	1.84	1.84	24.00	0.00	
27.09.2025	69.99	49.54	20.45	70.71	71.65	-1.31	1.44	1.44	1.44	24.00	0.00	
28.09.2025	70.07	64.67	5.40	80.13	78.93	1.51	0.44	0.44	0.44	24.00	0.00	
29.09.2025	70.63	51.45	19.18	61.73	69.20	-11.42	1.08	1.08	1.08	24.00	0.00	
30.09.2025	72.18	42.26	29.92	57.33	73.71	-25.01	1.71	1.71	1.71	24.00	0.00	
Средние:	68.45	57.56	10.89	---	---	-5.91	---	---	---	---	---	
Итого:	---	---	---	1379.96	1455.49	---	15.69	15.69	15.69	720.00	0.00	

Дата	m1	m2	W4	W5	W6	Тнар	Тпр
	т	т	ГКал	ГКал	ГКал	ч	ч
31.08.2025	203736.81	206930.08	6538.07	6538.07	6538.07	92382.44	5343.36
30.09.2025	205116.77	208385.57	6553.76	6553.76	6553.76	93102.44	5343.36
Итого:	1379.96	1455.49	15.69	15.69	15.69	720.00	0.00

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Дружбы ул, д. 23 (ООО "УК "МАСТЕР КОМФОРТА" Дружбы 23, 23а, 23б)
Прибор: ТСРВ-033(034) Заводской номер: 1001627
Точка измерения: ТС1 (Дружбы, 23Б (6-7 под.)); Ресурс: ТС

Датчик температуры:
Подача: ВЗЛЕТ ТПС SN 1002565/1
Обратка: ВЗЛЕТ ТПС SN 1002565/2
Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	t2	dt	m1	m2	%	W4	W5	W6	Тнар	Тпр	NS	NSCodes
	°C	°C	°C	т	т		ГКал	ГКал	ГКал	ч	ч		
01.09.2025	62.48	50.54	11.94	16.02	16.23	-1.30	0.19	0.19	0.19	24.00	0.00		
02.09.2025	63.79	51.85	11.94	18.56	19.00	-2.35	0.22	0.22	0.22	24.00	0.00		
03.09.2025	66.16	56.23	9.93	25.85	26.48	-2.39	0.26	0.26	0.26	23.98	0.03	*	2
04.09.2025	68.24	60.20	8.04	28.97	29.56	-2.03	0.24	0.24	0.24	24.00	0.00		
05.09.2025	66.54	58.50	8.04	28.45	29.12	-2.34	0.23	0.23	0.23	24.00	0.00		
06.09.2025	66.30	58.15	8.15	28.42	29.12	-2.42	0.23	0.23	0.23	24.00	0.00		
07.09.2025	66.51	58.17	8.34	28.98	29.69	-2.44	0.24	0.24	0.24	24.00	0.00		
08.09.2025	67.73	60.20	7.53	31.97	32.75	-2.43	0.24	0.24	0.24	24.00	0.00		
09.09.2025	71.24	65.53	5.71	44.35	45.34	-2.20	0.26	0.26	0.26	24.00	0.00		
10.09.2025	67.70	60.06	7.64	33.30	33.64	-1.01	0.26	0.26	0.26	24.00	0.00		
11.09.2025	67.81	59.77	8.04	31.98	32.61	-1.94	0.26	0.26	0.26	23.98	0.02	*	2
12.09.2025	67.29	58.39	8.90	26.23	26.73	-1.87	0.24	0.24	0.24	24.00	0.00		
13.09.2025	68.07	59.22	8.85	27.86	28.37	-1.81	0.25	0.25	0.25	24.00	0.00		
14.09.2025	69.38	61.00	8.38	29.78	30.30	-1.71	0.25	0.25	0.25	24.00	0.00		
15.09.2025	67.70	57.60	10.10	28.20	28.70	-1.75	0.29	0.29	0.29	24.00	0.00		
16.09.2025	67.43	57.67	9.76	25.61	26.04	-1.65	0.25	0.25	0.25	24.00	0.00		
17.09.2025	67.78	57.61	10.17	25.80	26.18	-1.46	0.26	0.26	0.26	24.00	0.00		
18.09.2025	69.06	60.08	8.98	30.24	30.50	-0.86	0.27	0.27	0.27	24.00	0.00		
19.09.2025	68.56	60.09	8.47	28.86	29.15	-0.99	0.25	0.25	0.25	24.00	0.00		
20.09.2025	68.71	60.33	8.38	28.72	29.08	-1.23	0.24	0.24	0.24	24.00	0.00		
21.09.2025	69.64	60.05	9.59	28.63	29.09	-1.58	0.28	0.28	0.28	24.00	0.00		
22.09.2025	67.22	44.08	23.14	25.35	25.69	-1.35	0.59	0.59	0.59	24.00	0.00		
23.09.2025	68.80	40.18	28.62	35.71	36.45	-2.04	1.02	1.02	1.02	24.00	0.00		
24.09.2025	69.65	44.87	24.78	48.89	49.85	-1.94	1.21	1.21	1.21	24.00	0.00		
25.09.2025	69.92	43.96	25.96	46.19	47.14	-2.03	1.20	1.20	1.20	24.00	0.00		
26.09.2025	70.15	43.42	26.73	43.49	44.38	-2.01	1.16	1.16	1.16	24.00	0.00		
27.09.2025	69.86	43.29	26.57	45.12	46.07	-2.09	1.20	1.20	1.20	24.00	0.00		
28.09.2025	69.80	44.71	25.09	49.74	50.80	-2.11	1.25	1.25	1.25	24.00	0.00		
29.09.2025	70.35	42.52	27.83	43.69	44.68	-2.24	1.22	1.22	1.22	24.00	0.00		
30.09.2025	71.76	44.01	27.75	46.13	47.13	-2.15	1.28	1.28	1.28	24.00	0.00		
Средние:	68.19	54.08	14.11	---	---	-1.86	---	---	---	---	---		
Итого:	---	---	---	981.07	999.82	---	15.35	15.35	15.35	719.96	0.04		

Дата	m1	m2	W4	W5	W6	Тнар	Тпр
	т	т	ГКал	ГКал	ГКал	ч	ч
31.08.2025	70540.13	71441.72	2379.67	2379.67	2379.67	61123.45	2423.64
30.09.2025	71521.20	72441.55	2395.02	2395.02	2395.02	61843.40	2423.68
Итого:	981.07	999.82	15.35	15.35	15.35	719.96	0.04

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Дружбы ул, д. 23 (ООО "УК "МАСТЕР КОМФОРТА" Дружбы 23, 23а, 23б)
Прибор: ТСРВ-033(034) Заводской номер: 1101798
Точка измерения: ТС1; Ресурс: ТС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	t2	dt	m1	m2	%	W4	W5	W6	Тнар	Тпр	NS
	°C	°C	°C	т	т		ГКал	ГКал	ГКал	ч	ч	
01.09.2025	56.62	47.37	9.25	21.94	22.03	-0.40	0.20	0.20	0.20	24.00	0.00	
02.09.2025	57.77	49.60	8.17	25.59	25.68	-0.37	0.21	0.21	0.21	24.00	0.00	
03.09.2025	63.93	56.97	6.96	36.20	36.33	-0.34	0.25	0.25	0.25	24.00	0.00	
04.09.2025	68.61	62.21	6.40	40.77	40.90	-0.34	0.26	0.26	0.26	24.00	0.00	
05.09.2025	66.87	60.35	6.52	40.24	40.37	-0.33	0.26	0.26	0.26	24.00	0.00	
06.09.2025	66.59	60.31	6.28	40.33	40.46	-0.32	0.26	0.26	0.26	24.00	0.00	
07.09.2025	66.82	60.20	6.62	41.17	41.31	-0.34	0.27	0.27	0.27	24.00	0.00	
08.09.2025	67.99	62.23	5.76	45.19	45.32	-0.30	0.26	0.26	0.26	24.00	0.00	
09.09.2025	71.40	67.10	4.30	62.25	62.39	-0.23	0.27	0.27	0.27	24.00	0.00	
10.09.2025	67.91	62.41	5.50	46.27	46.40	-0.28	0.26	0.26	0.26	24.00	0.00	
11.09.2025	68.04	61.82	6.22	44.10	44.24	-0.32	0.28	0.28	0.28	24.00	0.00	
12.09.2025	67.62	60.58	7.04	36.05	36.18	-0.37	0.26	0.26	0.26	24.00	0.00	
13.09.2025	68.38	61.28	7.10	37.64	37.78	-0.37	0.27	0.27	0.27	24.00	0.00	
14.09.2025	69.69	62.35	7.34	41.28	41.44	-0.39	0.31	0.31	0.31	24.00	0.00	
15.09.2025	68.01	60.55	7.46	39.09	39.24	-0.39	0.29	0.29	0.29	24.00	0.00	
16.09.2025	67.76	60.99	6.77	35.52	35.64	-0.35	0.24	0.24	0.24	24.00	0.00	
17.09.2025	68.13	60.66	7.47	35.63	35.77	-0.39	0.27	0.27	0.27	24.00	0.00	
18.09.2025	69.34	62.62	6.72	41.34	41.49	-0.35	0.28	0.28	0.28	24.00	0.00	
19.09.2025	68.82	62.40	6.42	39.53	39.67	-0.34	0.26	0.26	0.26	24.00	0.00	
20.09.2025	68.98	63.96	5.02	39.40	39.50	-0.26	0.20	0.20	0.20	24.00	0.00	
21.09.2025	69.90	61.24	8.66	39.34	39.52	-0.46	0.34	0.34	0.34	24.00	0.00	
22.09.2025	67.55	46.54	21.01	36.63	36.99	-0.98	0.77	0.77	0.77	24.00	0.00	
23.09.2025	69.05	43.61	25.44	54.16	54.84	-1.24	1.38	1.38	1.38	24.00	0.00	
24.09.2025	69.83	48.89	20.94	74.87	75.67	-1.07	1.57	1.57	1.57	24.00	0.00	
25.09.2025	70.06	48.43	21.63	70.86	71.64	-1.10	1.54	1.54	1.54	24.00	0.00	
26.09.2025	70.27	47.60	22.67	67.53	68.31	-1.15	1.53	1.53	1.53	24.00	0.00	
27.09.2025	70.02	47.96	22.06	70.42	71.21	-1.12	1.56	1.56	1.56	24.00	0.00	
28.09.2025	69.88	48.47	21.41	77.96	78.81	-1.09	1.67	1.67	1.67	24.00	0.00	
29.09.2025	70.45	47.13	23.32	68.57	69.39	-1.18	1.60	1.60	1.60	24.00	0.00	
30.09.2025	71.86	48.70	23.16	72.12	72.99	-1.19	1.67	1.67	1.67	24.00	0.00	
Средние:	67.94	56.48	11.45	---	---	-0.58	---	---	---	---	---	
Итого:	---	---	---	1421.95	1431.49	---	18.82	18.82	18.82	720.00	0.00	

Дата	m1	m2	W4	W5	W6	Тнар	Тпр
	т	т	ГКал	ГКал	ГКал	ч	ч
31.08.2025	59069.34	58554.03	1374.80	1374.80	1374.80	22584.50	1445.99
30.09.2025	60491.30	59985.51	1393.62	1393.62	1393.62	23304.50	1445.99
Итого:	1421.95	1431.49	18.82	18.82	18.82	720.00	0.00

Представитель абонента

Представитель энергоснабжающей организации