

Отчет о суточных параметрах  
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Студенческая ул, д. 18 (ООО "УК "МАСТЕР КОМФОРТА")  
Прибор: Карат-30X Заводской номер: 13071721  
Точка измерения: Подсистема 1; Ресурс: TC

Схема измерений: Пользовательская схема узла учета потребителя

| Дата       | t1    | t2    | dt    | V1       | V2       | M1       | M2       | P1      | P2      | %     | Q1     | Траб  | NS | igNSCode |
|------------|-------|-------|-------|----------|----------|----------|----------|---------|---------|-------|--------|-------|----|----------|
|            | °C    | °C    | °C    | м3       | м3       | т        | т        | кгс/см2 | кгс/см2 | т     | Гкал   | ч     |    |          |
| 01.11.2025 | 68.38 | 37.65 | 30.73 | 42.517   | 43.484   | 41.618   | 43.207   | 3.61    | 2.86    | -3.75 | 1.279  | 24.0  |    | Ok       |
| 02.11.2025 | 68.17 | 37.16 | 31.01 | 42.222   | 43.259   | 41.334   | 42.992   | 3.64    | 2.90    | -3.93 | 1.282  | 24.0  | *  | HC G     |
| 03.11.2025 | 72.04 | 37.20 | 34.84 | 41.546   | 42.533   | 40.580   | 42.270   | 3.61    | 2.89    | -4.08 | 1.414  | 24.0  | *  | HC G     |
| 04.11.2025 | 75.93 | 38.23 | 37.70 | 42.530   | 43.309   | 41.444   | 43.024   | 3.63    | 2.87    | -3.74 | 1.563  | 24.0  |    | Ok       |
| 05.11.2025 | 70.85 | 37.59 | 33.29 | 43.825   | 43.956   | 42.836   | 43.678   | 3.67    | 2.88    | -1.95 | 1.427  | 24.0  |    | Ok       |
| 06.11.2025 | 67.52 | 36.71 | 30.81 | 44.795   | 43.691   | 43.869   | 43.430   | 3.69    | 2.89    | 1.01  | 1.352  | 24.0  |    | Ok       |
| 07.11.2025 | 68.03 | 37.87 | 30.16 | 47.493   | 46.241   | 46.499   | 45.943   | 3.78    | 2.87    | 1.20  | 1.403  | 24.0  |    | Ok       |
| 08.11.2025 | 68.13 | 38.19 | 29.95 | 47.483   | 46.226   | 46.486   | 45.922   | 3.81    | 2.90    | 1.22  | 1.393  | 24.0  |    | Ok       |
| 09.11.2025 | 68.12 | 36.49 | 31.63 | 41.652   | 40.572   | 40.777   | 40.333   | 3.57    | 2.89    | 1.10  | 1.290  | 24.0  |    | Ok       |
| 10.11.2025 | 69.17 | 37.15 | 32.03 | 43.865   | 42.747   | 42.918   | 42.484   | 3.67    | 2.90    | 1.02  | 1.375  | 24.0  |    | Ok       |
| 11.11.2025 | 70.34 | 37.06 | 33.28 | 42.750   | 41.734   | 41.798   | 41.478   | 3.64    | 2.91    | 0.77  | 1.391  | 24.0  |    | Ok       |
| 12.11.2025 | 72.84 | 37.68 | 35.16 | 43.399   | 42.443   | 42.370   | 42.172   | 3.64    | 2.88    | 0.47  | 1.490  | 24.0  |    | Ok       |
| 13.11.2025 | 72.54 | 37.45 | 35.09 | 43.165   | 42.216   | 42.149   | 41.951   | 3.64    | 2.89    | 0.47  | 1.480  | 24.0  |    | Ok       |
| 14.11.2025 | 69.28 | 37.15 | 32.13 | 44.829   | 43.693   | 43.858   | 43.424   | 3.71    | 2.89    | 1.00  | 1.410  | 24.0  |    | Ok       |
| 15.11.2025 | 67.67 | 37.17 | 30.49 | 45.855   | 44.460   | 44.904   | 44.185   | 3.71    | 2.86    | 1.61  | 1.370  | 24.0  |    | Ok       |
| 16.11.2025 | 68.86 | 36.45 | 32.41 | 42.815   | 41.564   | 41.898   | 41.319   | 3.54    | 2.80    | 1.39  | 1.358  | 24.0  |    | Ok       |
| 17.11.2025 | 73.92 | 37.39 | 36.53 | 42.569   | 41.497   | 41.533   | 41.237   | 3.54    | 2.80    | 0.72  | 1.518  | 24.0  |    | Ok       |
| 18.11.2025 | 68.83 | 35.64 | 33.18 | 41.191   | 40.052   | 40.310   | 39.828   | 3.48    | 2.80    | 1.20  | 1.338  | 24.0  |    | Ok       |
| 19.11.2025 | 68.24 | 37.09 | 31.16 | 45.905   | 44.618   | 44.938   | 44.344   | 3.69    | 2.83    | 1.33  | 1.401  | 24.0  |    | Ok       |
| 20.11.2025 | 71.10 | 39.82 | 31.21 | 43.150   | 42.000   | 42.171   | 41.681   | 3.62    | 2.87    | 1.17  | 1.316  | 24.0  | *  | HC Tmin  |
| 21.11.2025 | 74.47 | 37.74 | 36.73 | 43.464   | 42.464   | 42.392   | 42.192   | 3.65    | 2.88    | 0.47  | 1.558  | 24.0  |    | Ok       |
| 22.11.2025 | 70.34 | 36.37 | 33.97 | 42.549   | 41.510   | 41.601   | 41.267   | 3.61    | 2.87    | 0.81  | 1.414  | 24.0  |    | Ok       |
| 23.11.2025 | 70.21 | 36.42 | 33.79 | 43.041   | 41.980   | 42.086   | 41.733   | 3.65    | 2.90    | 0.84  | 1.423  | 24.0  |    | Ok       |
| 24.11.2025 | 72.95 | 37.09 | 35.86 | 42.974   | 42.037   | 41.953   | 41.779   | 3.65    | 2.90    | 0.42  | 1.505  | 24.0  |    | Ok       |
| 25.11.2025 | 69.42 | 36.29 | 33.13 | 42.388   | 41.366   | 41.466   | 41.124   | 3.62    | 2.88    | 0.83  | 1.374  | 24.0  |    | Ok       |
| 26.11.2025 | 70.34 | 36.09 | 34.25 | 41.661   | 40.889   | 40.734   | 40.654   | 3.63    | 2.91    | 0.20  | 1.395  | 24.0  |    | Ok       |
| 27.11.2025 | 72.89 | 37.23 | 35.66 | 42.872   | 42.277   | 41.855   | 42.015   | 3.69    | 2.91    | -0.38 | 1.493  | 24.0  |    | Ok       |
| 28.11.2025 | 72.16 | 36.86 | 35.30 | 42.925   | 42.321   | 41.925   | 42.065   | 3.70    | 2.91    | -0.34 | 1.480  | 24.0  |    | Ok       |
| 29.11.2025 | 70.04 | 36.71 | 33.33 | 43.435   | 42.824   | 42.476   | 42.568   | 3.71    | 2.89    | -0.22 | 1.416  | 24.0  |    | Ok       |
| 30.11.2025 | 67.61 | 35.42 | 32.19 | 41.582   | 40.893   | 40.721   | 40.668   | 3.62    | 2.87    | 0.13  | 1.311  | 24.0  |    | Ok       |
| Средние:   | 70.35 | 37.11 | 33.23 | ---      | ---      | ---      | ---      | 3.65    | 2.88    | 0.03  | ---    | ---   |    |          |
| Итого:     | ---   | ---   | ---   | 1300.447 | 1278.856 | 1271.500 | 1270.966 | ---     | ---     | ---   | 42.220 | 720.0 |    |          |

| Дата       | V1        | V2        | M1        | M2        | Q1       | Траб    |
|------------|-----------|-----------|-----------|-----------|----------|---------|
|            | м3        | м3        | т         | т         | Гкал     | ч       |
| 31.10.2025 | 52125.160 | 52260.590 | 50677.730 | 51760.820 | 1723.310 | 36850.3 |
| 30.11.2025 | 53425.610 | 53539.450 | 51949.230 | 53031.790 | 1765.530 | 37570.3 |
| Итого:     | 1300.450  | 1278.860  | 1271.500  | 1270.970  | 42.220   | 720.0   |

Представитель абонента

Представитель энергоснабжающей организации